# PRESSED STEEL SECTIONAL WATER TANKS







### **GENERAL SPECIFICATIONS**

#### Standard:

NUCO pressed steel sectional water tank constructed with hydraulically pressed flanged panels, conform to BS 1564 : 1975 and SS22 : 1979

#### Materials:

The steel used in the manufacture of the tank plates, stays and cleats conform to the requirements of BS 4360 : 1972 grade 43A or ISO equivalent

#### Flanges of Plates:

Tank panels pressed with a combined double flange at an angle of 45 degree and 90 degree to the face of the plate on four sides

#### **Stays and Cleats:**

The stays and cleats are made of steel angle bar and steel plate

#### Bolt, Nuts, Washers:

Hot Dipped Galvanised steel bolts, nuts and washers for internal and external

#### **Jointing Materials:**

Non toxic PVC foam to be used for all jointing between tank panel flange

#### Tank Cover:

Panel type steel cover supported by trusses 600mm x 600mm square manhole and 100mm airvent supplied as standard for each compartment

#### Water Level Indicator:

Reverse Reading Pointer Mechanical Type (Cat & Mouse)

#### Nozzles for Connection:

Short pipe with flange or socket for all pipe connections

#### Ladder:

Aluminium or HDG Steel ladder for internal and external access

#### Finish:

Hot Dip Galvanised conform to ISO 1461

# Standard Thickness for 1.22m x 1.22m Tank Panel

1.22m(H)	2.44m(H)	3.66m(H)	4.88m(H)
			5mm
		5mm	5mm
	5mm	5mm	5mm
5mm	5mm	5mm	5mm
5mm	5mm	5mm	5mm
	<b>1.22m(H)</b> 5mm 5mm	1.22m(H)         2.44m(H)           5mm         5mm           5mm         5mm           5mm         5mm	1.22m(H)         2.44m(H)         3.66m(H)           5mm         5mm         5mm         5mm           5mm         5mm         5mm         5mm           5mm         5mm         5mm         5mm

#### Standard Thickness for 1m x 1m Tank Panel

Туре	1.0m(H)	2.0m(H)	3.0m(H)	4.0m(H)	5.0m(H)
5th side panels					5mm
4th side panels				5mm	5mm
3rd side panels			5mm	5mm	5mm
2nd side panels		5mm	5mm	5mm	5mm
1st side panels	5mm	5mm	5mm	5mm	5mm
Bottom panels	5mm	5mm	5mm	5mm	5mm



#### 1. Scope

This British Standard specifies requirement for pressed steel sectional rectangular tanks, working under a pressure not greater than the static head corresponding to the depth of the tanks, built up of pressed steel plates 1220mm square used to contain cold water, hot water, potable liquids, certain oils and chemicals. Tanks may be constructed as follows:

(a) with external flanges;

(b) with internal bottom flanges, external side and end flanges.

Two types are specified:

*Type 1* With a combined double flange at an angle of 45° and 90° to the plane of the plate on all four sides as illustrated in figure 1. The plates of type 1 tanks are hot pressed complete.

*Type 2* With a single flange at an angle of **90** the plane of the plate on each of two, there or four sides, depending on its position in the tank. Type 2 tanks are old pressed as illustrated in figure 2, with the flange corners welded. This standard does not provide for tanks subject to earth or other external pressure other than wind pressure.

#### NOTE: For an illustration of a typical tank external

flanges see figure 8. For approximate weights and full nominal capacities (without freeboard) of open top tanks see tables 1 to 4.

Tanks can also be assembled with all flanges internal with the addition of other components, but because of the difficulty of assembling and maintaining this type of tank they are not preferred. All tanks can be supplied with open or closed top. Information on erection and supports is also included.

#### 2. References

The titles of the British Standards referred to in this standard are listed on the inside back cover.

# 3. Information to be supplied with the enquiry and order

The following information, as appropriate, should be supplied by the purchaser with his enquiry or order.

(a) Type of tank required (clause 1), type of cover (if any), number and position and type of manhole(s), number of divisions if required.
(b) Capacity required in liters or dimensions in millimeters in multiples of 1220mm and whether any provision is to be made for future extension and if any level indicators are required.

(c) Limiting conditions, if any, as to space and accessibility for erection, and whether the tank

will be erected in a building or exposed to the weather, and the height above ground level it is to be installed.

(d) Nature and density of liquid for which the tank is required. if corrosive, particulars to be given. If water, state whether hard or soft. The rate of filling and emptying the tank, head fluctuations and cycles per day.

(e) Maximum and minimum temperatures and approximate rate of fluctuation and position of heating elements.

(f) Any special requirements as to jointing material and as to internal and external coating or lagging.

#### NOTE: In the absence of any special requirements

one coat of a suitable priming paint will be applied to protect the tank during delivery and erection. A minimum of two further coats should be applied after erection.

(g) Particulars of connections and drilling required and precise location on tank with dimensioned sketches, having regard to possible future requirements.

(h) Whether external access ladders are required and, if so, particulars to be given.

(i) Details of any existing or proposed supporting structure and height of bottom of tank above ground level so that the necessary scaffolding arrangements can be made to comply with statutory safety regulations.

(j) Whether transverse supporting bearers are required and, if so, particulars as to span and end support to be given.

(k) Whether the tank is to be used for other than a stationary application.

(I) Whether inspection will be made by the representative of the purchaser at the works of the manufacturer.

(m) Whether erection is to be carried out by the manufacturer at site; if so, information as to site conditions and accessibility to be given by the purchaser.

#### 4. Working temperatures

For the purpose of this standard cold liquids are defined as those having a temperature not exceeding 38°C and hot liquids are defined as those having a temperature exceeding 38°C but less than 100 °C. In the case of tanks to hold hot liquids, care shall be taken in use to avoid excessive vibration or turbulence. Tanks for temperatures higher than 100 °C should be the subject of mutual arrangement between the purchaser and the manufacturer.



#### 5. Materials

5.1 The steel used in the manufacture of the plates, stays, cleats and pads for connections shall conform to the requirements of BS 4360: 1972 grade 43A or BS 1449: Part 1: 1972 material HR 14. 5.2 Bolts, studs, nuts and washers shall be made from steel complying with the requirements of BS 4190. Bolts and nuts shall be hexagonal, black finish, screwed ISO metric complying with the requirements of BS 4190, where applicable. Washers shall comply with the requirements of BS 4320: 1968 from 'F'.

#### 6. Dimensions of unit plates

The nominal size of unit plates shall be 1200mm square. The actual overall dimensions depending upon the particular manufacturer of the plates. The size of tanks shall be specified as multiples of the nominal dimension.

#### 7. Thickness of unit plates

7.1 For cold liquids with a density not exceeding 1.0 the nominal thickness of the plate from which the unit plates are pressed shall be not less than:

#### Tanks 1220mm in depth:

<ul> <li>bottom, sides and ends</li> </ul>	5mm
Tanks 2440mm in depth:	
<ul> <li>bottom, sides and ends</li> </ul>	5mm
Tanks 3660mm in depth:	
<ul> <li>bottom, sides and ends</li> </ul>	5mm
Tanks 4880mm in depth:	
<ul> <li>bottom, and first tier of</li> </ul>	
sides and ends	6mm
<ul> <li>second, third and top tiers of</li> </ul>	
sides and ends	5mm

7.2 For hot liquids with a density not exceeding 1.0 no plate shall less than 6mm in thickness.

7.3 For cold or hot liquids with a density greater than 1.0 the plate thicknesses shall be a matter for mutual arrangement between the purchaser and the manufacturer.

#### 8. Permissible stresses

The calculated stress in any stay and attachment and bolts shall comply with the requirements of BS 449, and any allowance that may be required for corrosion shall be added to the calculated thickness.

#### 9. Flanges of plate

Plate shall be pressed with a combined double flange at an angle of 450 and 900 to the face of the

plate on all four sides (type 1 figure 1) or a single flange at an angle of 90o to the plate on each of two, three or four sides (type 2 figure 2), the flanges holed according to the respective position of the plate in the tank and free from irregularities. The width of the flanges shall be not less than 45mm, the holes for the bolts having a clearance of 1.5mm in diameter, the bolts having a minimum diameter of 14mm (M14). The spacing of bolts holes shall not exceed 76.2mm pitch.

#### 10. Jointing material

The jointing to be used for tanks shall be suitable for the conditions and shall be a matter for mutual agreement between the purchaser and manufacturer. Any jointing used shall be insoluble in the liquid to be stored and, where necessary, shall be non-toxic.

#### 11. Bolts, studs, nuts and washers

Bolts, studs, nuts and washers shall be in accordance with the requirement specified in 5.2. Ech flange bolts shall be fitted with one flat washer under the nut and the diameter of the bolts shall be not less than 14mm (M14).

#### 12. Staying

12.1 The sides and ends of all tanks shall be supported by stays at the junction of two or more plates the stays shall made from mild steel rolled sections calculated in accordance with clause 7. Stays shall be attached to the plates by bolting to cleats of equal strength bolted to tank plates; stay attachments to cleats and cleats to tank plates shall be calculated taking into account eccentricity of loading. The ends of the stays shall be attached to the cleats or tank plates by bolts. 12.2 Stays shall connect sides to bottom, ends to bottom and/ or horizontally sides and sides to ends generally in accordance with figure 8.

#### 13. Connections

13.1 Pads for connections, tapped bosses, screwed flanges or sockets, as may be required by the purchaser, shall be welded to the inside or outside or bolted to the tank plate. Pads shall be drilled, and/ or tapped as necessary to suit flanges complying with the requirements of BS4504, or such other standard as specified by the purchaser. Single pads shall be provided for connection on one side of the plate and double pads for connection on both sides of the plate. Tapped socks shall comply with the requirements specified in BS 1387. Typical types of welded connections are shown in figures 3 to 7.



#### 14. Welding of connections

Welds for connections shall be made by the metal are process complying with the requirements of BS 1856 and by means of covered electrodes complying with the requirements of BS 639: 1972 sections 1 and 2: grade 1.

#### 15. Supports

All tanks shall effectively supported in accordance with the manufacturer's recommendations and tolerances. Supports shall be provided continuously under each bottom flange in one direction at 1220mm centers. Tanks with internal bottom flanges can also rest directly on a flats level base. A sand/bitumen bed 50mm thick is recommended at that case. Where steel joints are used they shall be designed to carry the imposed load with a maximum deflection of one fivehundredth of the span. Attention is drawn to the extra reaction on the supports under the side, end and division plates when the stays of sides, ends and divisions are inclined to the bottom of the tank.

#### 16. Closed top tanks

16.1 Cover framing members shall be designed to withstand superimposed loadings complying with the requirements of BS 449.

16.2 Covers may be flat indoor use and should be pitched or cambered for outdoor use, and jointed to ensure that they are dust and weather proof.16.3 Covers may be constructed of steel plates or other constructional cladding materials.

16.4 In all cases closed top tanks shall be provided with a manhole of not less than 460mm diameter clear opening to give access to the inside of the tank and with a suitable vent, filtered if necessary, to the manufacturer's requirements to avoid pressure changes within the tank.

#### 17. Access Ladders

Tanks over 1220mm deep shall be provided with a steel internal access ladder. In covered tanks the ladder shall be adjacent to the manhole.

# NOTE: External ladders may be provided required;

attention is drawn to BS 4211.

#### 18. Marketing

All tanks complying with the requirements of this standard shall be legibly marked as follows. (a) Manufacturer's name, mark or initial. (b) The number of this British Standard, i.e. BS 1564.

#### 19. Minimum access

Where tanks with external flanges are to be erected in a confined space it is essential that a clearance of not less than 500mm shall be provided all round the outside and underneath to facilitate erection. For access to the top of a closed tank the clearance at the top shall be not less than 750mm.

*NOTE:* Allowance should be made for inspection and maintenance including valves or other external fittings.

#### 20. Inspection

20.1 Works inspection. The purchaser or his representative shall have access to the works of the manufacturer at all reasonable times and shall be at lliberty to inspect and to reject any material which does not comply with the requirements of this standard. Such inspection shall include verification that the unit plates will mate together and assemble. where partial or complete assembly is required at the works of the manufacturer, this shall be the subject of specific arrangement between the purchaser and the manufacturer at the time of enquiry and order.

20.2 Site inspection. The purchaser or his representative shall ensure that supports are within the tolerances required by the manufacturer before the commencement of erection.

#### 21. Erection

Erection shall be carried out in accordance with the manufacturer's instructions.

#### 22. Testing

Testing shall be filling the tank with water on site and shall be the subject of specific arrangement between the purchaser and the manufacturer at the time of the enquiry and order. Wter for testing shall be supplied by the purchaser.

# **GRP SECTIONAL WATER TANKS**







GRP & PRESSED STEEL SECTIONAL WATER TANKS



# **GENERAL SPECIFICATIONS**

# Standard:

1995 similiar to British Standard BS 7491 Part3:1994 and BS EN 13280:2001

# Materials:

Sheet Moulding Compound (SMC) consists of:

Resin - Isophthalic unsaturated polyester resin conforming to BS 3532 specification Fibre Glass - Low alkali fibre glass conforming to JIS R3411 to R3417 or BS 3396, BS 3496 and BS 3749 specifications

# **Manufacturing Process:**

Hot pressed SMC compression moulding

# Tank Structural Support:

Tie-rod System :	External: Hot Dipped Galvanised Steel	
	Internal: SS 304 Tie-rod, Optional SS316	
Roof Support:	PVC/ABS pipes with GRP roof panel stiffener	
External Braced System:	External: Hot Dipped Galvanised Steel	
	<b>Internal:</b> None (metal free inside, non-partitioned tank only)	
Roof Support:	PVC Poles with GRP roof panel stiffener	

#### Sealant:

Non toxic PVC foam/EPDM Rubber

#### **Bolt, Nuts, Washers:**

External:	Standard: Hot Dipped Galvanised Steel
	<b>Optional:</b> SS 304/316
Internal:	Standard: SS 304 (In-contact with water)
	<b>Optional:</b> SS 316 (In-contact with water)
External:	Standard: Hot Dipped Galvanised Steel
	<b>Optional:</b> SS 304/316
Roof:	Standard: Hot Dipped Galvanised Steel
	<b>Optional:</b> SS 304/316

# Ladder:

External: Internal: Standard: Hot Dipped Galvanised Steel Standard: PVC or Aluminium Optional: GRP or SS 304/316

#### Water Level Indicator:

Standard: Reverse Reading Pointer Mechanical Type (Cat & Mouse) Optional: Direct Reading Clear Tube Type

#### Nozzle Panel:

Pipe nozzles not inclusive Flat panels will be provided on request

\*Note: Specification may vary according to client's requirement.



# **BASE PANEL**







**TOP PANEL** 



Base Panel 1m x 1m

Base Panel 1m x 0.5m

- Top Panel 1m x 1m
- Top Panel 1m x 0.5m

SIDE PANEL



# **PERFORMANCE OF PANELS**

Characteristics	NUCO GRP Tank Panel Performance	Acceptance Criteria (SS 245:1995 Specification)
Tensile strength (MN/m <sup>2</sup> )	103	>70 (min)
Bending strength (MN/m <sup>2</sup> )	170	>100 (min)
Elastic Modulus in Bend (MN/m <sup>2</sup> )	13580	>6000 (min)
Glass content (%)	39	>25 (min)
Barcol Hardness	59	>30 (min)
Water absorption (%)	0.05	1.0 (max)



# NOZZLE / FLAT PANEL





1m x 1m

Nozzle/Flat Panel 1m x 0.5m

# MANHOLE



Manhole 1m x 1m

# **PRE-INSULATED PANEL**



Top Panel 1m x 1m



By encapsulating a 25mm ~ 50mm layer of rigid polyurethane foam, NUCO preinsulated panel could maintain the desired water temperature stored inside the tank under extreme temperature condition. NUCO pre-insulated panel could be selected for water storage where there is a need to stabilize the temperature against extreme heat or freezing conditions so to prevent dew formation.

# **QUALITY ASSURANCE**



